

NAWA WATER CHEMICAL PROFILE					
					2/6/2008
<u>WATER PARAMETER</u>		<u>Vandalia</u>	<u>Tipp City</u>	<u>MCL</u>	
Alkalinity Total, as CaCo3 mg/l		120	120	N/A	
Chlorine Residual, as mg/l		.8 - 1.2	.8 - 1.2	4	
Fluoride Total, as mg/l		1	1	4	
Hardness Total, as mg/l		140	140	N/A	
Hardness Total, as grains/gallon		8.2	8.2	N/A	
Iron Total, as mg/l		0.02	0.02	0.3	(SMCL)
Nitrate-Nitrite, as mg/l		BDL	BDL	10	
Manganese Total, as mg/l		0.019	0.019	0.05	(SMCL)
PH		7.6	7.6	N/A	
Phosphorous Total, as mg/l		0.48	0.48	N/A	
Sodium, as mg/l		13.2	13.2	N/A	
Total Coliform		NEG	NEG	NEG	
Turbidity (NTU)		<1	<1	1	
MCL = Maximum Contaminate Level					
SMCL = Secondary Maximum Contaminant Level					
mg/l = Milligrams per Liter or Parts Per Million					
NEG = No Coliform Bacteria Present					
< = less than					
BDL= Below Detection Level					